



City of Quincy, Massachusetts
Purchasing Department
1305 Hancock Street
Quincy, MA 02169

Phone: 376-1060
Fax: 376-1074

ADDENDUM NUMBER 1

RE: BID/RFP DUE : NOVEMBER 1, 2012 @ 11:00 a.m.

BID/RFP TITLE: TREE PLANTING PROJECT

PLEASE NOTE :

Here are some questions and answers that have been asked by potential bidders:

Q.) Can the excavated material for the tree pit be amended and used as backfill material, or do we need to use screened loam for tree pit backfill?

A.) Screened loam

Q.) Please confirm the length of the tree maintenance period --- does the maintenance period run the full length of the 1-year warranty period?

A.) Yes, the maintenance period runs concurrently with the warranty period (1 year).

Thank you.

PLEASE SIGN THIS SHEET AND ATTACH IT TO YOUR BID, AS IT IS NOW A PART OF THE BID. "ADDENDUM MUST BE SIGNED OR BID WILL NOT BE ACCEPTED."

Kathryn R. Hobin
Purchasing Agent

Date: _____

Bidder's Signature: _____