



City of Quincy, Massachusetts
Purchasing Department
1305 Hancock Street
Quincy, MA 02169

Phone: 376-1060

Fax: 376-1074

ADDENDUM NUMBER 2

RE: **BID DUE: OCTOBER 24, 2013 @ 11:00 a.m.**

BID/RFP TITLE: ELLIS ST. HAMILTON ST. & VICTORIA RD WATER MAIN REPLACEMENT

To be considered as part of the contract drawings and specifications for the Ellis Street, Hamilton Street, and Victoria Road Water Main Replacements.

SPECIFICATIONS

SECTION 02080 – DUCTILE IRON PIPE AND FITTINGS FOR WATER MAINS

1. Add the following paragraph to section 3.04:

“D. All hydrostatic pressure tests shall be certified and signed off on by an independent third party, who is insured and experienced in AWWA water line testing procedures and standards. The third party certification shall be paid for at the CONTRACTOR’s expense. The OWNER will not accept pressure tests that have not been certified by an independent third party.”

SECTION 02514 – HYDRANTS AND VALVES

1. Delete paragraph 2.02.G in its entirety and replace with the following paragraph:

“G. For purposes of standardization, hydrants shall be Mueller "Super Centurion," Model 250 (with or without their AquaGrip System) as manufactured by Mueller Co., Decatur, IL; or Darling B-62-B as manufactured by American Flow Control, Beaumont, TX; or **“approved equal”**.”


SECTION 02515 – SERVICE CONNECTIONS (WATER SERVICES)

1. Delete paragraph 2.03.C in its entirety and replace with the following paragraph:

“C. Curb stops shall be Catalogue #B44-444-Q by Ford Meter Box Co., Inc., Wabash, IN; Mark II Oriseal Model #H-15219 (with drain) by Mueller Co., Decatur, IL; Series 262 by Cambridge Brass Inc., Cambridge, ON; or by A.Y. McDonald, Dubuque, IA; or **“approved equal”**.”

Thank you.

PLEASE ACKNOWLEDGE ALL ADDENDA ON YOUR BID FORM.



Kathryn R. Hobin
Purchasing Agent