




City of Quincy
City Hall
1305 Hancock Street
Quincy, Massachusetts 02169
Purchasing Department



ADDENDUM NUMBER 7

RE: **Town Brook Enhancement Project – Phase 2A Addendum No. 7**

BID DATE: 2/2/2012

BID TITLE: Town Brook Enhancement Project – Phase 2A

PLEASE NOTE THE FOLLOWING REVISIONS:

1. ENGINEER'S FIELD OFFICE

The Contractor may be required to provide Field Office to in accordance with Section 740 of the Standard Specifications, and shall be **Type "B"** as detailed in the Standard Specifications, **NOT** Type "A" as previously required per Addendum 5. All other requirements and provisions as previously described in these Contract Documents shall apply as detailed for Bid Item 14 – "Engineer's Field Office and Equipment". Page B-4 for the "Form for General Bid" has been included as Attachment 1 to this Addendum including this revision for Bid Item 14, and shall replace the previously issued Page B-4. The Contractor shall complete and submit this bid form with the Bid package.

2. LIST OF SUBCONTRACTORS

Paragraph 5 on Page 8 (Item 17 "TRENCHLESS CONSTRUCTION SPECIFICATIONS & BID REQUIREMENTS:" as detailed in Addendum 5, of these Contract Documents shall be replaced with the following:

*"The Contractor shall include the "List of Subcontractors" and accompanying "Statements of Experience" and the "Materials/Equipment Questionnaire" included in Appendix 4. These shall be completed and submitted with each bid on the forms included with the Bid Form and Attachments. The Bidders may submit **one** subcontractor or supplier for a particular work activity. If, after due investigation, Owner or Engineer has determined that any proposed Subcontractor, Supplier, material, equipment, or other individual or entity, does not meet the requirements stated in the relevant technical specification section, the City may, before the Notice of Award is given, request the apparent low Bidder to submit an acceptable substitute without an increase in the Bid. Declining to make requested substitutions **will** constitute grounds for sacrificing the bid security of any Bidder. Any Subcontractor, Supplier, or other individual or entity so listed and against which Owner or Engineer makes no written objection prior to the giving of the Notice of Award will be deemed acceptable to Owner and Engineer, subject to revocation of such acceptance after the Effective Date of the Agreement as provided in the Supplementary Conditions. Contractor shall not be required to employ any Subcontractor, individual, or entity against whom Contractor has a reasonable objection."*

Page B-20 "List of Subcontractors" has also been revised to change "New Castle County" to "City of Quincy", and is included as Appendix 2 to this Addendum. This form shall replace the previously issued "List of Subcontractors", and the Contractor shall complete and submit this bid form with the Bid package.

3. TRANSITION STRUCTURE

The transition structure at approximate Station 33+25 as shown on sheet C-8 included as part of Alternative Work Item 5 shall be included as part of this Contract and shall be designed by the precast culvert manufacturer in accordance with Section 02240 "Precast Reinforced Concrete Drainage Structure" and all applicable sections of these Contract Documents and Standard Specifications. Shop Drawings shall be submitted for review and approval in accordance with Section 01300 "Submittals". The proposed reinforced box culvert shall be laid according to the grades and slopes as shown on the Plans, and shall match the invert of the existing culvert at the connection to the existing Town Brook culvert. Based on available record information, the existing Town Brook culvert interior dimensions are 9'(w) x 5'-6"(h). For the purposes of Bidding, the Contractor shall assume the transition from the existing 9'(w) x 5'-6"(h) culvert to the proposed 11'(w) x 6'(h) culvert will be accomplished in a single precast culvert section, and shall bid accordingly. The connection to the existing culvert will be made with a closure pour as shown on Sheet S-5 of the Plans.

4. IMPERMEABLE LINER

Impermeable Liner/Membrane shall be constructed with earth cover as described in the "Report on Geotechnical Design" prepared by Haley & Aldrich, Inc. on January 17, 2012, and shall be sealed to retaining walls or footings with compatible mastic or similar adhesive, to achieve a relatively watertight connection, for at least 8 inches height at the top as described in the Geotechnical Report.

Thank you. PLEASE SIGN AND ATTACH IT TO YOUR BID, AS IT IS NOW PART OF THE BID.

Kathryn R. Hobin, Purchasing Agent

Date: _____

Bidder's Signature: _____

Attachments:

- Attachment 1 - Revised Form for General Bid (Pg. B-4)
- Attachment 2 - Revised Subcontractor's List to Accompany Bid (Pg. B-20)



Attachment 1

Revised Form for General Bid (Pg. B-4)



THIS PAGE INTENTIONALLY LEFT BLANK

Item No.	Lump Sum Price in Both Words & Figures	Estimated Quantity	Extended Amount
12.	Private Utility Relocations	1	\$60,000
	Per Allowance		
	Sixty Thousand Dollars and		
	Zero Cents		
	(\$)		
13.	Miscellaneous Excavation	1	\$100,000
	Per Allowance		
	One Hundred Thousand Dollars and		
	Zero Cents		
	(\$)		
14.	Engineer's Field Office and Equipment (Type B)	9	
	Per Month		
	Dollars and		
	Cents		
	(\$)		

SUBTOTAL PAGE B4 \$ _____

SUBTOTAL PAGE B2 \$ _____

SUBTOTAL PAGE B3 \$ _____

SUBTOTAL PAGE B4 \$ _____

TOTAL BID AMOUNT \$ _____

(IN FIGURES)

 (TOTAL BID AMOUNT WRITTEN IN WORDS)



Attachment 2

Revised Subcontractor's List to Accompany Bid

(Pg. B-20)



THIS PAGE INTENTIONALLY LEFT BLANK

SUBCONTRACTORS LIST TO ACCOMPANY BID

This form, listing subcontractors to be used by _____ in performing The Town Brook Enhancement Project – Phase 2A Contract, is hereby made a part of this proposal. Bidders are advised that this list shall be a part of the bid submission and binds the Prime Contractor to use the subcontractors so designed unless receiving written consent from the City of Quincy for replacement. Bids submitted without completion of the following list and required statement of qualifications are subject to rejection.

CONTRACTOR shall list all intended subcontractors including firm name, primary business address and the intended general scope of work for the Town Brook Enhancement Project.

Qualifications and past experience shall be attached for all tunneling and jack and bore subcontractors.

Name	Address	Scope of Work