



City of Quincy, Massachusetts
Purchasing Department
1305 Hancock Street
Quincy, MA 02169

Phone: 376-1060

Fax: 376-1074

ADDENDUM NUMBER 3

RE: BID DUE : July 28, 2011 @ 11:30 A.M.

BID/RFP TITLE: Roof Replacement at Lincoln-Hancock School

Addendum #3

The attention of Bidders submitting proposals for the above, mentioned project located in Quincy, Massachusetts, is called to the following information to the Contract Documents. The following additions, clarifications, and/or deletions shall hereby include in their entirety within the scope of the Contract Documents and shall, in turn, form a part of the Proposals submitted for Bid.

PART 1 - GENERAL


- 1.1 The following additions, clarifications, and/or deletions shall hereby be included in their entirety within the scope of the Contract Documents and shall, in turn, form a part of the Proposals submitted for Bid.

PART 2 - DRAWINGS

- A. Revision of the following details on Sheet A-502
1. Detail 4/A-502, Revised Detail Attached
 2. Detail 8/A-502, Revised Detail Attached

Thank you.

PLEASE SIGN THIS SHEET AND ATTACH IT TO YOUR BID, AS IT IS NOW A PART OF THE BID.



Kathryn R. Hobin
Purchasing Agent

Date: _____

Bidder's Signature: _____

CONSULTANTS:

PROJECT:
**LINCOLN-HANCOCK
ELEMENTARY
ROOF
REPLACEMENT**

300 GRANITE STREET
QUINCY, MA

CLIENT:
**THE CITY OF
QUINCY**
QUINCY, MA

**NOT FOR
CONSTRUCTION**

PREPARED BY A LICENSED ARCHITECT.
Any changes to this item can be a violation of the law unless altered by a licensed architect. Any alteration made to this item must be accompanied by a specific description of change or changes made, date change was made, as well as the seal of the licensed architect who made or oversaw the changes.


MARK	DATE	DESCRIPTION
7/26/11		ADDENDUM NUMBER 3
7/13/11		ISSUED FOR BID

PROJECT NO.:	11117
DRAWN BY:	MVM/DN
CHECKED BY:	SJW
DRAWING SCALE:	6"=1'-0"


SHEET TITLE:
**NEW
CONSTRUCTION
ROOF DETAILS**

SHEET:
A-502


DO NOT SCALE DRAWING




3 THROUGH WALL SCUPPER DETAIL
SCALE: 6"=1'-0"



2 TYPICAL ROOF COMPONENTS DETAIL @ CONNECTOR ROOF
SCALE: 6"=1'-0"




1 TYPICAL ROOF COMPONENTS DETAIL @ POOL & GYM ROOFS
SCALE: 6"=1'-0"




8 ROOF EDGE AT POOL AND GYM
SCALE: 6"=1'-0"

- NOTES:
- 1) PRIME FLANGE OF EDGE METAL PRIOR TO FLASHING PLY INSTALLATION
 - 2) RUN SELF-ADHERING VAPOR RETARDER OVER BLOCKING AND ON TO CONCRETE CURB.


6 NOT USED
SCALE: NA



5 TYPICAL CONNECTOR ROOF PARAPET DETAIL
SCALE: 6"=1'-0"



4 TYPICAL SHELF EDGE DETAIL
SCALE: 6"=1'-0"



7 WALL EDGE DETAIL @ LOWER, CONNECTOR ROOF
SCALE: 6"=1'-0"

Drawing name: A-502(11117) Lincoln-Hancock Elementary - 1108(Revised) Consultant Document(1117)_Access:Access_07/26/11_10:40:00 AM

COPYRIGHT © STEPHEN J. WESSLING ARCHITECTS INC. 2011