



City of Quincy, Massachusetts  
Purchasing Department  
1305 Hancock Street  
Quincy, MA 02169

Phone: 376-1060

Fax: 376-1074

**ADDENDUM NUMBER 1**

**RE: BID DUE : March 26, 2013 @ 11:00 a.m.**

**BID/RFP TITLE: FENCE BID**

**PLEASE NOTE :**

**Addendum #1**

Several questions have been asked by potential bidders for clarification:

- Q. In the General Specifications portion, under Galvanized Chain Link Systems ---it calls for a 2oz. zinc coating. On Detail #7 General Palmer it sites 1.2oz, coating please clarify? Also Wendal Moses is a Galvanized System but the detail does not call out either. This is important because 2oz. is a special item and the 1.2oz is a standard product.
- A. *The zinc coating at both locations would be 2.0 ounces.*
- Q. What diameter are the line posts for each of the projects? Will they be larger on the corners?
- A. *Pipe sizes for 6-foot, 8-foot and 10-foot high fences:  
Terminal/corner posts – 3-inch OD  
Line posts – 2.5-inch OD*
- Q. Can you confirm the size of the fabric? The cover sheet says 6 ga core wire for both types of fence and the drawings list 9 ga steel for Wendell Moses and Perkins and 6 ga fabric for General Palmer field.
- A. *6 gauge core fabric at all locations.*
- Q. Is removal of the existing fences part of this contract? Or will that be done separately?
- A. The City will take down the old fence before we do the earthwork.

Thank you.

**PLEASE ACKNOWLEDGE THIS ADDENDUM IN YOUR BID AS IT IS NOW A PART OF THE BID.**

**Kathryn R. Hobin  
Purchasing Agent**